

STATIC 1½ HOUR LABEL FIRE DAMPER VERTICAL & HORIZONTAL MOUNT

MODEL 51BXS-SS • TYPE B



OPTIONAL CONSTRUCTION



 UL 555 & CAN/ULC-S112 Classified Static Fire Damper, 11/2 Hr. Label (File # R25565).

• NFPA 80, 90A & 101 compliant.

• NBC and IBC building codes compliant.

STANDARD CONSTRUCTION

DEPTH: 41/4" (108).

FRAME: Roll formed Type 304 Stainless Steel with hemmed edge.

BLADES: Roll formed Type 304 Stainless Steel.


Interlocking curtain type.


FUSIBLE LINK: 165°F (74 C).

☐ Type 316 Stainless Steel Construction. ☐ Factory Supplied Sleeve – 22, 20, 18 or 16 Ga.

Sleeve Length Required. □ 212°F (100 C) Fusible Link.

□ 1½" x 1½" Retaining Angles.





MODEL 51BHS-SS (HORIZONTAL MOUNT)



FIRE DAMPER COMPONENTS

1. S.S. Blades 2. Fusible Link Assembly

5. S.S. Blade Stack Cover 6. S.S. Constant Force Spring

3. S.S. Link Strap

7. S.S. Lock Ramp

4. S.S. Frame

MAINTENANCE RECOMMENDATIONS:

NFPA 80 advises that fire dampers be inspected and tested 1 year after installation, then every 4 years minimum. More frequent inspections may be required due to system use and air conditions, or applicable local codes.

NOTES:

These static dampers are UL//ULC approved for use in HVAC systems where the fans automatically shut down in the event of a fire alarm. 11/2 hr. labeled fire dampers are suitable for use in fire separations with a fire resistance rating of 2 hours or less.


Fire dampers must be installed in accordance with manufacturer's instructions. Refer to Alumavent installation instructions for details.




STATIC 1½ HOUR LABEL FIRE DAMPER VERTICAL & HORIZONTAL MOUNT

MODEL 51BXS-SS • TYPE B


SINGLE SECTION DAMPER -VERTICAL MOUNT



SINGLE SECTION DAMPER -HORIZONTAL MOUNT



MULTIPLE SECTION DAMPER -VERTICAL MOUNT ONLY



NOTE: SEE TYPE B STAINLESS STEEL STATIC 11/2 HOUR SIZING CHART SC51BS-SS FOR OVERALL DAMPER DIMENSIONS.

REF.#	QTY.	DUCT WIDTH (W)	DUCT HEIGHT (H)	MOUNT (V/H)	ACCESSORIES

^{*}DAMPER WILL BE MANUFACTURED APPROXIMATELY 1/2" (6) SMALLER THAN GIVEN DUCT DIMENSIONS.

PROJECT NAME:	ENGINEER:
CONTRACTOR:	SUBMITTAL DATE: